



# Certificate of Compliance

THIS CERTIFICATE IS ISSUED FOR THE FIG. #1GK RIGID COUPLING  
FOR USE IN ABOVEGROUND SPRINKLER SYSTEMS

- 1-1/4, 1-1/2, 2, 3, 4 inch and 76.1 mm at a rating of 500 psi (3450 kPa)
- 139.7, 165.1 and 216.3 mm at a rating of 300 psi (2070 kPa)

Prepared for: **JINAN MEIDE CASTING CO, LTD.**  
**NO. 3 NANMEN ROAD,**  
**PINGYIN, JINAN, SHANDONG**  
**P. R. CHINA 250400**


<u>Approval Identification:</u>	<u>Approval Granted:</u>	<u>FM Approvals Class</u>
3040577	December 7, 2010	1920

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.*



*Member of the FM Global Group*

  
Richard B. Dunne,  
Manager- Hydraulics Group  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062

December 7, 2010