



# Certificate of Compliance

This certificate is issued for the following:

## Gasketed Pipe Fittings for Use with Aboveground Fire Protection Systems

Model 1G Rigid Coupling with a Rated Working Pressure of 500 PSI (3445 kPa)

Model 1GS Rigid Coupling with a Rated Working Pressure of 350 PSI (2415 kPa)

Model 1N Flexible Coupling with a Rated Working Pressure of 500 PSI (3445 kPa)

Model 1NH Flexible Coupling with a Rated Working Pressure of 750 PSI (5170 kPa)

For Use with Aboveground Steel Fire Sprinkler Pipe

### Prepared for:

Jinan Meide Casting Co Ltd  
No 3 Nanmen Rd  
Pingyin Jinan, 250400  
China

### Manufactured at:

Jinan Meide Casting Co Ltd  
No 3 Nanmen Rd  
Pingyin Jinan, 250400  
China

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”

Approval Identification: 3058500

Approval Granted: September 23, 2016

Reissued: October 13, 2016

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D B. Fuller'.

David B. Fuller  
AVP, Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



Member of the FM Global Group